

Kitemark™ Certificate

This is to certify that:

Tyco Fire Products LP
One Stanton Street
Marinette
Wisconsin
54143
USA

Holds Certificate Number:

KM 804125

In respect of:

BS EN 17446:2021
Fire Extinguishing Systems in Commercial kitchens

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2024-04-11

Latest Issue: 2024-04-11

Effective Date: 2024-04-11

Expiry Date: 2027-04-10

Page: 1 of 2



Kitemark™ Certificate

No. KM 804125

Description	Model No	Additional Info	Branded As
Commercial Kitchen Fire Suppression System to BS EN 17446:2021. 11.4L / 3 US Gallon Capacity (11 flow units) ANSULEX LPH Wet Chemical per tank, Maximum 15 tanks per system, Cartridge Operated, Temperature Activated (multiple temperature options) or Manual Activated. Offering appliance specific and overlapping tested design options.	ANSUL R-102 Restaurant Fire Suppression System	Can be used on the following kitchen hazards: Deep Fat Fryer, Griddle, Range Top, Braising Pan/Tilt Skillet, Gas Radiant Char-Broiler, Electric Char-Broiler, Duct, Plenum.	Ansul

See Product Manual for Further Details

First Issued: 2024-04-11
 Latest Issue: 2024-04-11

Effective Date: 2024-04-11
 Expiry Date: 2027-04-10

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
 To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).