



asbl ANPI vzw  
Parc Scientifique Fleming - Granbonpré 1  
B-1348 Louvain-la-Neuve

**ANPI**

**CERTIFICATE OF CONFORMITY**

Certificate nr: **1635703-ANPI-2-c**  
Holder of the Certificate: Ansul SA  
Industrialaan 35  
1702 Groot-Bijgaarden  
Belgium  
  
Manufacturer: **Ansul**  
Material: **Fixed extinguishing module for the industrial deep  
friers**  
  
Brand: **Ansul**  
Type: R102

Based on the conformity with NT113:2008, ANPI Admin Legal rules (2018.02.16) and ANPI Other Products rules (2020.01.07)

Report: BFS/ME/046 & ADD 1

**This certification is only valid for the fixed fire extinguishing modules provided with an ANPI-label.**

The use of the ANPI-labels (colour: blue) has to be kept in a register per type of certified module. This has to be available at all times when ANPI asks for it and has to be up to date. Those labels (rolls of 500 labels) can only be purchased at asbl ANPI vzw (ANPI Division Certification) and may not be counterfeit.

This certificate is based on the system 2 of the ISO/IEC 17067:2013.

This certificate is delivered in accordance with the general rules of the ANPI brand and is valid until 21.12.2025. This certificate may be reproduced in its original form.

**Louvain-la-Neuve, 10 August 2023**

  
**Certification Manager**

Phone : +32 10 47 52 11 – Fax : +32 10 47 52 70 - [www.anpi.be](http://www.anpi.be)



Annex 1 to ANPI certificate of conformity  
Number: 1635703-ANPI-2-c

10 August 2023  
Annex 1, page 1/1

## R102

- Foam (extinguishing agent) 3G or 1,5 G Ansulex
- Sparklet: cartridge carbon dioxide 101-10/101-20/101-30/Nitrogen LT-20-R/LT-30-R/Double Tank Cartridge/LT-A-101-30
- Cabinet: Automan mechanical regulated release (60\*42\*20cm)  
mounting box  
basic decoupling with regulator  
basic decoupling with electromagnetic contact switch and regulator  
self drilling bolt  
distance piece  
spring clip  
supporting lever and construction  
bolt  
locking ring  
hexagonal screws  
warning label  
packing  
construction cartridge for pressurisation  
construction for container 1.5/3.0 GAL  
construction for pipe  
cover (label included)  
solenoid  
switch type "snap action"  
closing bolt  
clip screw
- Reservoir extinguishing agent and dip tube
- Manual control
- Electrical contact
- Ejector nozzle on standard container: 1W/1N/1/2N/3N/2W/230/245/260/290/2120/1F
- Cabinet with pneumatic trigger
- Transmission pulley
- Threaded coupling inox RVS/INOX/55
- Inox detection duct 18x1mm
- Inox cable: 15 m/152m
- Inox extinguishing duct: 15x1mm / 3/8 S40
- Inox junctions
- Extinguishing duct 1,5 M
- Flexible duct